

13.9.98

FAX MESSAGE

From: G.L.Somani,
Dy.Chief Engineer (Mech.Mtc.)
Kota Thermal Power Station,
RSEB Kota.
Fax No.0744- 450061.

For: M/s.HI-TECH SYSTEMS & SERVICES LTD.,
B-15, Narayna Vihar, 1st floor,
New Delhi.
Fax No.(011) 579 0775.

Repeat M/s.Instrumentation Ltd.,
Kota.
Fax No.0744- 424322.

Sub:-Performance of Level State Electronic Drum
Level Indicator installed & commissioned at
Kota Thermal Power Station-Unit V.

On the subject it is to inform that the Level State
Electronic Drum Level Indicator supplied, installed and
commissioned by M/s.Instrumentation Ltd., Kota in Unit-V
1x210 MW Stage-III is satisfactory working since Jan.'98 (.)

It is also reported that the modifications carried out
in the High-pressure Vessel as well as Conducting Electrodes
is also satisfactory (.)

(G.L.Somani) 11/11/98
Dy. Chief Engineer (Mech.Mtc.)
KTPS RSEB Kota.

Ref:KTPS/RSEB/Dy.CE(Mech.Mtc.)/98/D. 3419
Kota, Dated the 11th Nov. 1998.

PCC: M/s.HI-TECH SYSTEMS & SERVICES LTD.,
New Delhi.

PCC: M/s. Instrumentation Ltd.,
Kota.

Dy. Chief Engineer (Mech.Mtc.)