

RENUSAGAR POWER COMPANY LIMITED

REGD. OFFICE :
P. O. RENUKOOT
PIN : 231 217
DIST. SONBHADRA U. P.
PHONE : PIPRI 79
GRAM : RENUPOWER
RENUKOOT

WORKS :
P. O. RENUSAGAR
PIN : 231 218
DIST. SONBHADRA U. P.
PHONE : PIPRI 90 141 142
GRAM : RENUPOWER
RENUKOOT

Ref. Inst/ 94/378 /63

Dated March 29, 1994

M/s. Hitech Systems & Services Ltd.
White House
19, Park Street
Calcutta 700 016

Kind Attn. Mr. Vikash Agarwal:


Dear sirs,

Sub: Performance report of 1 set of level state
Electronic Drum level Indicator 202 system:

One set of level state electronic drum level indicator 202 system supplied against our Purchase Order No. 4535/PUR:INS(5)-3225 dt. 30.9.92 was commissioned on 30th January 1993. The system is working quite satisfactorily and no failure of electrode or any electronic component has occurred till now.

Thanking you,

Yours faithfully,
for Renusagar Power,
A Divn of Hindalco Industries Ltd.,


(GC Singhal)
Dy.C.E. (Instrument)